

TYRE district WATER assessment*

Village	Available Capacity	Damage	Needs	Existing Families	Returned Families
Arzoun	1 Water Tank	-Primary Network 200m -Secondary Network 400m	-Network repair	(N/A)	(N/A)
Bustan	-2Water Tanks -Water available	-Water Tank partially Damaged. -Water network damaged in one area	Electrical power	(N/A)	(N/A)
Jibal Alboutom	-2water tanks -1water source	-water network 900m damaged	-1water pump -1generator -Water network repair		
Jibyne	-1water tank	(N/A)	(N/A)	(N/A)	(N/A)
Mahlousieh	-2water tanks -1water source(private)	-water network partially damaged	-1Water generator		
Kahirri	-1water tank	(N/A)	(N/A)	(N/A)	(N/A)
Barrish	-2water tanks -1water source	-1water tank damaged -water network damaged(the station)	-Electrical power	(N/A)	(N/A)
Bazourieh	-2water tanks	No Damage reported	-Electrical power	(N/A)	(N/A)
Bedias	-2water tanks -1water source	No Damage reported	-Electrical power	(N/A)	(N/A)
Borj shamali	-2water tanks	-Water network partially damaged	-Fuel	(N/A)	(N/A)
Borj rahal	-2water tanks -1water source	-Water network partially damaged 200m	-Water network repair	(N/A)	(N/A)

Jouya	-3water tanks	-6 tanks totally damaged	-Fuel, water tanks.	(N/A)	(N/A)
Hanaweh	-1 water tank -1Generator	-water network partially damaged	-Network repair -Generator maintenance	(N/A)	(N/A)
Dibaal	-2water tanks -1water source	-Main line (residential) not operational -Main Network 20m damage -Internal Network 200m damage	-Network repair -Electrical power	(N/A)	(N/A)
Shaityeh	-Water network operational			(N/A)	(N/A)
Yanouh	-Water network operational	(N/A)	-Water network needs maintenance -water tank	(N/A)	(N/A)
Mansouri	-1water tank -1water source -water 90% available	-water network partially damaged	-Fuel for the Generators	(N/A)	(N/A)
Atoulyeh	-1water tank -Water network operational			(N/A)	(N/A)
Dayr Kanoun Naher	-1water tank -1water source	-Secondary network 600m damage	-Network repair -Water source maintenance -Electrical power	200	170
Dayr K. Ras alEin	-2water tanks (surrounded by cluster bombs)	-Main network 300m damage -Secondary network 200m damage	-Network repair -Water source	(N/A)	(N/A)
Dayr Kayfa	-1water tank -water source	-Secondary network 150m damage.	-Network repair -Electrical power	(N/A)	(N/A)
Ribkeen	-1Water source	- Main network 1000m damage	-Network repair -Electrical power	(N/A)	(N/A)

Salaa	-2Water tanks	(N/A)	-Water source	(N/A)	(N/A)
Shhour	-2Water tanks -1Water source	-water pump not operational	-Maintenance for the water pump	(N/A)	(N/A)
Shamaa	-1Water tank -Main network operational	-Secondary network not operational	-Network repair	(N/A)	(N/A)
Shahabieh	-1water tank	- Main network 1000m damage -Secondary network damaged but being repaired	-Network repair	(N/A)	(N/A)
Shihiine	-1water tank	-water tank partially damaged -Main & Secondary network partially damaged.	-Network repair	(N/A)	(N/A)
Sidikine	-2Water tanks	- Main network 5000m damage -Secondary network 70000m damage	- Network repair	(N/A)	(N/A)
Srifa	-2Water tanks	-Water network damaged	-Network repair -150KVA generator	(N/A)	(N/A)
Tayr Harfa	-2Water tanks -Water network operational	(N/A)	(N/A)	(N/A)	(N/A)
Borghliee	(N/A)	(N/A)	(N/A)	(N/A)	(N/A)
Aljibin	(N/A)	(N/A)	(N/A)	(N/A)	(N/A)
Shknanieh	(N/A)	(N/A)	(N/A)	(N/A)	(N/A)
Bafleh	(N/A)	(N/A)	(N/A)	(N/A)	(N/A)

Village	Available Capacity	Damage	Needs	Existing Families	Returned IDPs
Tayr Fleh	-1Water source	- Main network operational except for minor problems	-Network maintenance -Electrical power	(N/A)	(N/A)
Aitite	-3Water tanks	- Main network 100m damage -Secondary network 2500m damage	-Network repair -1Generator	(N/A)	(N/A)
Ain Ebl	-4Water tanks -1Water source	- Main network partially damaged -water pump not operational	-Maintenance for the water pump -Network repair	(N/A)	(N/A)
Kana	-1Water tank -Main network operational	-Secondary network not operational	-Network repair	(N/A)	(N/A)
Klayle	-5water tank	- Main network 1000m damage -Secondary network damaged but being repaired	-Network repair	(N/A)	(N/A)
Majadel	-1water tank	- Main network 100m damage	-Network repair -1Generator	(N/A)	(N/A)
Majdel zoun	-2Water tanks	- Main network 5000m damage -Secondary network 70000m damage	- Network repair	(N/A)	(N/A)
Mahroune	-1Water tanks	-Water network damaged	-Network repair -150KVA generator	(N/A)	(N/A)
Marwaheen	-2Water tanks -1Water source	- Main network not operational.	-Network repair	(N/A)	(N/A)

Mazraa Meshref	-1Water source -1Water tank	- Main network operational except for minor problems	-Network maintenance -Electrical power	(N/A)	(N/A)
Maarakeh	-4Water tanks	(N/A)	-Network repair -1Generator	(N/A)	(N/A)
Yareen	-1Water tanks -1Water source	- Main network operational except for minor problems	-Network repair	(N/A)	(N/A)

TYRE district includes 70 villages and 57 Municipalities

Total # of assessed villages: 42 villages

***UNICEF assessment team**

***Municipalities official information**