



5182 / 1
14 / 2 / 2020

Syrian Arab Red Crescent
Shakib Arslan Street, Abu Rummaneh,
P.O Box 3790, Damascus, Syria
Te: 00963 11 3327645/153 Fax: 00963 113327695

REQUEST FOR QUOTATION
General Items
(IT equipment-Furniture-Generator-Medical equipment)

The Syrian Arab Red Crescent (SARC), also referred to in this document as 'Purchaser', supported by UNFPA kindly request your best firm offer for the following:

1. Type and Quantity:

Information on the items, specifications and quantities are stated in "**Annex1: Detailed Technical Specifications/Technical Offer Form**"

2. Delivery Terms:

Items are to be delivered to SARC's warehouse in Damascus.

Notes: The purchaser reserves the right to increase or decrease the listed quantities during the tender process.

3. Delivery Date:

The selected supplier will be given a maximum of /15/ days to complete deliveries. The purchaser reserves the right to change this delivery period if the tendering period takes longer than expected. Specific information on delivery dates will be provided in the contract.

4. Quality specifications:

Goods offered must meet Syrian standards and the minimum specifications indicated in "**Annex 1: Detailed Technical Specifications/Technical Bid**".

5. Alternatives:

Alternative specifications *may be accepted on condition that the varying specifications are clearly indicated in Annex 1 (Technical Bid) and the alternatives are found to be as suitable as the requested specifications. The decision on whether to accept alternatives will be the sole responsibility of the purchaser and will be final. Suppliers will not be allowed to make changes on specifications after expiry of bids submission period.*

6. Language:

All documents and markings shall be in **Arabic or English**.

7. Requirements:

- a) The planned final delivery points are SARC warehouses in Damascus in quantities that are indicated in "**2. Delivery Terms**"



- b) Due to the evolving environment in Syria, the purchaser reserves the right to move the destination of the ordered goods to any of the other locations mentioned in "2. Delivery Terms" where they deem more appropriate at the time.

8. Cost breakdown:

"Financial Offer" in annex /2/ is to be completed by supplier.

Prices should be inclusive of all applicable taxes, transportation to the final delivery address, loading and offloading, transit Insurance, and all other related costs involved.

Please provide your best CPT Damascus Warehouse (incoterms 2010) offer as there will be No price negotiation after opening of the bids

9. Currency:

All costs shall be fixed and firm in Syrian Pounds (SYP) only.

10. Inspection

I) Pre-shipment Inspection

The purchaser reserves the right to conduct a pre-shipment inspection of the items, 5 days prior to the delivery date or less by its own personnel or reputed third parties to confirm quantity and quality.

II) Final Inspection

A last inspection will be done by the purchaser or a third-party company, at the time of delivery at the destination. Supplies that fail to meet the required specifications will be rejected. The Purchaser reserves the right to reject part or whole of the consignments that contain unaccepted quality supplies. In case of partial rejection, the supplier will meet the total cost incurred in the process as will be determined by the Purchaser.

The selected bidder must offer the items for inspection in such a manner that it does not affect the delivery schedule.

11. Liquidated Damages Clause

Please be advised that delivery after the agreed schedule may be subject to a penalty from 0.1% per day up to a maximum of 20% of the total cost CPT value of the contract. If the delay lasts more than 30 days from the date agreed on the contract, the contract will be voided, penalties charged to the supplier; besides other actions related to non-performance of the contract.

12. Payment

As per Organization policy, no advance payment will be allowed, Payment will be done after receipt of goods; and all supporting documents in good order, including invoice.

Documents required for payment processing:

1. Commercial invoice / commercial receipt
2. Goods Receipt Note

13. Insurance

Suppliers will be responsible for Goods until they have been delivered and accepted by the Purchaser. All risks mitigation during the transportation from the supplier's location to the designated destination requested by the Purchaser will therefore be the responsibility of the Supplier.



14. All or None Clause:

The Purchaser reserves the right to accept the whole or part of the supplier's offer and the lowest priced bid will not be automatically accepted.

15. Conditions for submitting offers:

Suppliers do not have to submit an offer for all items listed in this tender as they can participate in a partial or full offer.

Offers must be received at the latest on **December 22, 2020 by 2:00 PM local time** or earlier if possible:

A- Each bidder shall submit /3/ different sealed envelopes marked as follows:

- **"Envelope 1: Administrative Documents"**: This envelope should have the following contents:
 - Bidder's company profile.
 - Performance bond (certified cheque from a well-known bank in Syria) with a value of 20,000,000- Twenty million Syrian pounds. In favour to Syrian Arab Red Crescent-HQ**, the cheque will be duly delivered to the winner after **successfully** completing the delivery process.
 - Business Registration/commercial Certificate.
 - SARC supplier registration form-filled signed and stamped.
 - Copy of this request for quotation stamped and signed.
 - Any testimonials/proof of past experience.
 - Note: Financial information **must not** be included in this envelope.*
 - **"Envelope 2: Technical Bid"**: This sealed envelope should have the following contents:
 - Annex 1: Detailed Technical Specifications/Technical Offer Form- Filled, signed and stamped
 - Any clarifications on products
 - Note: Financial information **must not** be included in this envelope.*
 - **"Envelope 3: Financial offer"**: This sealed envelope should have the following:
 - Annex 2: Financial Offer- filled signed and stamped
 - Any clarifications on pricing
 - Note: Any pricing clarifications that essentially changes the terms stated by the Purchaser, would be considered during evaluation and depending on the implied change, may negatively impact the bidder's potential to win the tender*
- B- The purchaser will not accept any addition / alterations / deletions of the Bid however; the purchaser reserves the right to request clarification or call for supporting documents from any of the bidders.**

The cover page/envelope shall clearly identify the sender and receiver (see below).

Please note that no pricing information must appear on this page.

Offers must be submitted in a sealed envelope sent to the following address:

Attn: Procurement Committee
Syrian Arab Red Crescent, Damascus
National Headquarter Office
Shakib Arslan Street, Abu Rummaneh
Ref.



The purchaser reserves the right to reject *Offers, which do not comply with the specified requirements.*

16. Validity

Your offer must be valid for 30 days, before which a Purchase Order, if placed shall be accepted by you.

17. Terms and Conditions:

Please note that all the pages of this document will form part of your bid. Please confirm your acceptance of information and conditions contained in this document as well as the terms and conditions; by signing all pages and sending back in the envelope marked "**Envelope1: Administrative Documents**", without financial information.

Supplier Registration Form:

Please fill in and return the attached Supplier Registration Form. The form should be included in the envelope marked "**Envelope 1: Administrative Documents**"

18. Performance Bond:

This is required for this procurement. By participating in this tender process, the supplier commits to abide by the terms and conditions of the tender including the liquidated damages clause mentioned in section 11 and the condition of laboratory testing.

Performance bond (certified cheque from a well-known bank in Syria) with a value of 20,000,000- Twenty million Syrian pounds. In favour to Syrian Arab Red Crescent-HQ; the cheque will be duly delivered to the winner after successfully completing the delivery process.

For unsuccessful bidders, the cheques will be duly delivered to them once the tender process is finalized by SARC within 20 days.

19. List of Documents and Annexes:

This request for quotation comes with the following list of documents:

Document	No. of pages	Included
Request for quotation	6	1. Declaration of Undertaking 2. Declaration of compliance
Annex 1	11	Technical Specification
Annex 2	11	Financial Offer
Annex 3	6	Supplier Registration Form

Thank you and best regards,

Syrian Arab Red Crescent President,

Mr. Khaled Hboubati





DECLARATION OF UNDERTAKING

For the attention of

Syrian Arab Red Crescent
SARC Headquarters
Street: Shakib Arslan Street, Abu Rummaneh
City: *Damascus*
Country: Syria

Subject: Declaration of Undertaking

Project Name: **General Items**

We the undersigned,

[Name, and address of the company],

Hereby declare that,

in emphasising the importance of a free, fair and competitive awarding procedure that precludes abuse, this company thus far has not offered or granted any inadmissible advantages either directly or indirectly to public servants or other persons in connection with this bid, nor shall it offer or grant any such incentives or rewards in the present awarding procedure or, in the case of an award, during the subsequent execution of the Agreement.

We shall inform our employees of their respective duties and their commitment to observe this self-imposed obligation.

Authorized Person

Name: _____ Designation: _____

Cell / Tel No: _____ E-mail: _____

Signature and stamp _____ Dated: _____



DECLARATION OF COMPLIANCE WITH ADMINISTRATIVE REQUIREMENTS

Description	To be filled in by bidder		To be filled in by SARC		
	Included?		Present & complete?		Comments
Step/ document to be submitted	Yes	No	Yes	No	
Tender package delivered before the deadline specified in the tender (Required)					
Supplier registration form – completed, signed & stamped (Required)					
Declaration forms signed and submitted (Required)					
3 separate sealed envelopes submitted for Administrative, Technical and Financial Bids (Required)					
Copy of company registration (Required)					
Copies of past contracts/ POs as proof of experience (Preferred)					
Relevant certifications and registration with Government bodies (Preferred)					
Quality certificates for goods offered (Preferred)					

N/B the Purchaser reserves the right to reject bids which do not meet administrative compliance irrespective of their technical and financial competitiveness.

I declare that the above information and documentation are true and correct.

Authorized Person

Name: _____ Designation: _____

Cell / Tel No: _____ E-mail: _____

Signature and stamp _____ Dated: _____

Annex 1: Technical Specification/Technical Offer form

#	Item	Requested Specifications	Offered Specifications (To be filled by the supplier)	Qty
1.	Desk	MDF (Medium-density fibreboard) wood covered with Formica - 120x60cm		14
2.	Rotating, office, chair	Leather with arms. Hydraulic, rotating, wheels, swivel,		14
3.	Files cupboard	200*80*40cm - wood - 4 doors		20
4.	Waiting chair	Without arms, plastic		40
5.	Stand coats	Wood		12
6.	Electric fan	standing		14
7.	Fan	Ground fan on battery		14
8.	Gas Heater	Indoor Gas heater, Equipped with wheels, Equipped with a gas leak control sensor		4
9.	Electric kettle	Capacity: 1.2 liter Weight (net) 1.0 kg Colour: Black/ White or Stainless steel Voltage: 230 V		10
10.	oven (3 heads)	3 heads		2
11.	water cooler	Good Quality , cold/hot with filter		2
12.	visitor chair ,rigid	Three Seater Waiting Chair - metal and leather		10
13.	AC(1 ton)	1 Ton - split case with cupboard pipes		12
14.	Refrigerator	<ul style="list-style-type: none"> •Top mount refrigerator: 1 upper freezer door and 1 lower refrigerator door •Automatic Defrost System includes a timer, a limit switch and heater that melts away frost so you don't have to take everything out of your freezer to melt built-up ice •7.74 cu. ft. fresh food compartment and 2.94 cu. ft. freezer compartment 		6
15.	Laptop	Intel core i5 with 4 cores, Turbo boost Technology, Hyper Threading, Generation 8th, Cache: 6M , RAM:8G , HDD: 1T,Screen : 15.6 inch, VGA card:2G, Battery: at least 4 hours		8
16.	Laser Printer	Laser Monochrome Printer, Multifunction: Printer, Copier, Scanner, Printing speed: minimum 18 ppm,Resolution: 1,200 dpi,Paper source: 2 Drawers, Paper feed: Automatic Sheet Feeder, Paper size: A4, A3,Memory Size: Minimum 64 MB, upgradeable		6
17.	TV LED 32 with receiver	Screen Size: 32" Display Type: LED Colour Depth: 16.7M colours Panel Type: IPS Refresh Rate: 60Hz Aspect Ratio: 16:9 Inputs: Multi Input Resolution: minimum 1920 x 1080		6

18.	Receiver	HDTV Satellite Receiver 1080p with multi satellites up to 2000 channels at least with HDMI Cable	2
19.	Photocopier	Functions: coping / printing Colour: Black & white Max. print speed: 18.0 ppm	2
20.	Telephone	Master, up to 8 lines, multi-transfers	2
21.	Finger printer	Display:2.8-inch TFT Colour Display/Fingerprint Capacity:3,000/ID Card Capacity: ID Card Capacity/Communication:TCP/IP, USB-Host, Wi-Fi/Standard Functions: Automatic Status Switch, Self-Service Query, Work Code, T9 Input, 9 Digit User ID, DST, Scheduled-bell,SMS,RS232 Printer AC module 1:Exit Button, Door Lock, Alarm,12V OUT,AUX IN/Optional Function: ID Card, MIFARE Card AC module 2: Exit Button, Door Lock, Alarm,12V OUT, AUX IN, Door Sensor, RS485, Wiegand IN/OUT. POE, 3G, Battery Module, ADMS/Power Supply:12V 1.5A/Logs Capacity:100,000	2
22.	Monitoring Cameras	DVR,Hard,power supply 50A,cable, TV LED 43	20
23.	20 مولدة كهرباء / K.V.A	المواصفات الفنية لمجموعة التوليد الكهربائية ذات الاستطاعة <u>(20 ك.ف.أ) كاتمة للصوت:</u> على العارض تقديم مجموعة توليد كهربائية استطاعتها (20 ك.ف.أ) عند موقع العمل، عند حالة العمل المستمر Prime power وعند توتر 380 فولت وتردد 50 هرتز لها المواصفات الفنية التالية: <u>أولاً. المواصفات العامة لمجموعة التوليد الكهربائية:</u> _ يجب أن تكون المجموعة المقدمة صناعة أو تجميع إحدى الشركات العالمية المتخصصة ويجب بيان الشركة الصانعة والمجموعة والماركة والطراز وبلد المنشأ للمجموعة بشكل واضح. _ يجب تحديد بلد المنشأ لكل مكونات مجموعة التوليد (محرك الديزل، المنوبة، الكابين، لوحة التحكم، القاطع الكهربائي) _ يجب تقديم شهادة جودة من شركة علمية موثوقة تثبت التقيد بمواصفات ال ISO 9001 للشركة الصانعة وشهادة ISO 9001 أو ISO 9002 للشركة المجمعاً لمجموعة التوليد الكهربائية وتكون هذه الشهادة سارية الصلاحية بتاريخ تقديم العرض	1

– يجب أن يتضمن العرض الفني المعلومات والمعطيات التالية ضمن المواصفات العامة:

1_ استطاعة المجموعة في موقع العمل عند حالة العمل المستمر Prime power لا تقل عن/20 ك.ف.أ/ بعد الأخذ بعين الاعتبار تدني الاستطاعة وفق شروط العمل. [حيث أن حالة عمل المجموعة هي الحالة المستمرة و المعرفة بـ (Prime Power/ PRP) والتي تنص :

إن حالة العمل لمجموعة التوليد بشكل مستمر (24/24 ساعة) و بعدد غير محدد من الساعات في السنة وبمتوسط حمل متغير حسب المواصفة القياسية ISO 8528-1 مع إمكانية زيادة 10% من الاستطاعة المستمرة للمجموعة لمدة (12 ساعة) وفق المواصفة القياسية ISO 3046-1 .

وعلى العارض أن يبين القيمة العظمى لمتوسط الحمل المتغير Variable Load الذي يمكن استجراره من استطاعة المجموعة ويجب أن لا تقل القيمة العظمى لمتوسط الحمل المتغير Average Load Factor عن 70% من الاستطاعة المستمرة للمجموعة كحد أدنى، ويفضل أن لا تقل تلك القيمة العظمى لمتوسط الحمل المتغير الذي يمكن استجراره من الإستطاعة المستمرة للمجموعة عن 80% .

2_ ظروف التشغيل للمجموعة (موقع العمل):

- درجة الحرارة (-5م° ← +40م° تقريباً).
- الرطوبة النسبية (65%) .

ويجب على العارض تقديم منحنيات وجداول تدني الاستطاعة لكل من المحرك و المنوبة مع درجة الحرارة والارتفاع

ثانياً . المواصفات الفنية لمحرك الديزل:

. يجب أن يكون محرك الديزل صناعة إحدى الشركات العالمية المتخصصة ويجب تقديم شهادة ISO 9001 للشركة الصانعة للمحرك سارية المفعول بتاريخ تقديم العرض، وعلى العارض بيان كافة المواصفات الفنية الأساسية والتصميمية للمحرك في عرضه الفني موثقة وموضحة بالنشرات الفنية وهي:

. الماركة والطراز وبلد المنشأ وسنة الصنع لمحرك الديزل .

. نوع المحرك ديزل رباعي الأشواط عمودي .

. عدد الأسطوانات وترتيبها وتوضع الأسطوانات .

. قطر الإسطوانة وطول الشوط، متوسط السرعة المكبسية، نسبة الإنضغاط، عدد الصمامات لكل إسطوانة.
. سعة الإسطوانة والسعة الكلية للمحرك.
. سرعة دوران المحرك (1500[r.p.m]) ويجب أن تتطابق مع سرعة واتجاه دوران المنوبة.
. إستطاعة محرك الديزل:
يجب أن تكون استطاعة المحرك كافية لتشغيل المنوبة وإعطاء الاستطاعة الفعلية المطلوبة لمجموعة التوليد وفق الاستاندرت العالمية والمواصفات القياسية ISO 8528 & ISO 3046 ويجب أن تحقق استطاعة محرك الديزل الشروط التالية :
حالة العمل لمجموعة التوليد هي الحالة المستمرة و المطلوب تقديم استطاعة المحرك عند حالة العمل المستمر المعرف بـ (Prime Power/ PRP) والتي تنص (إن حالة عمل مجموعة التوليد بشكل مستمر (24/24 ساعة) و بعدد غير محدد
• من الساعات في السنة و بمتوسط حمل متغير حسب المواصفة القياسية ISO 8528-1 مع إمكانية زيادة(10%) من الإسططاعة المستمرة للمجموعة لمدة ساعة خلال (12 ساعة) وفق المواصفة القياسية -ISO 3046
1).
وعلى العارض أن يبين القيمة العظمى لمتوسط الحمل المتغير Variable Load الذي يمكن استجراها من الإسططاعة المستمرة للمحرك Prime Power .
ويجب أن لا تقل القيمة العظمى لمتوسط الحمل المتغير Average Load Factor عن(70%) من الاستطاعة المستمرة للمحرك Prime Power كحد أدنى , ويفضل أن لا تقل تلك القيمة العظمى لمتوسط الحمل المتغير التي يمكن استجراها من الاستطاعة المستمرة للمحرك عن(80%) .
• الاستطاعة المطلوبة للمحرك هي الاستطاعة الصافية Net Power أي بعد حسم الاستطاعة التي تستهلكها مروحة التبريد من الاستطاعة الكلية للمحرك .

• يجب أن يؤخذ بعين الاعتبار منحنيات تخفيض الاستطاعة DE rating مع الحرارة والارتفاع والرطوبة حسب ظروف التشغيل لموقع العمل

• يجب أن لا تقل قيمة استطاعة المحرك الصافي Net Power عند حالة العمل المستمر Prime Power بعد الأخذ بعين الاعتبار منحنيات تخفيض الإستطاعة DE rating بحيث لا تقل عن استطاعة المنوبة الفعلية في موقع العمل عند نفس حال العمل المستمر ويفضل وجود احتياطي لإستطاعة المحرك على استطاعة المنوبة بعد الأخذ بعين الإعتبار تلك الشروط بحدود (5%) تقريباً .

(علماً أنه لا يؤخذ بالاعتبار مردود المنوبة عند حساب احتياطي استطاعة المحرك على استطاعة المنوبة)

ثالثاً . المواصفات الفنية للمنوبة الكهربائية:

يجب أن تكون المنوبة الكهربائية من صناعة إحدى الشركات العالمية المتخصصة ويجب تقديم شهادة ISO 9001 للشركة الصانعة للمنوبة سارية المفعول بتاريخ تقديم العرض .

وعلى العارض بيان كافة المواصفات الفنية الأساسية والتصميمية في عرضه الفني موثقة وموضحة بالنشرات الفنية

- الماركة والشركة الصانعة والطراز وبلد المنشأ وسنة الصنع للمنوبة الكهربائية.
- الاستطاعة المستمرة لا تقل عن (20 [KVA]) عند حالة العمل المستمر Continuous في موقع العمل بعد الأخذ بعين الاعتبار تدني الاستطاعة وفق ظروف موقع العمل .
- النوع: ثلاثية الأطوار مع حيادي . رباعية الأقطاب .
- توتر خرج المنوبة 380 فولت أو 400 فولت قابلة للتعبير بحيث يمكن الحصول منها على 380 فولت .
- التردد 50 هرتز .
- سرعة الدوران 1500 دورة/دقيقة .
- على العارض بيان قيم الاستطاعة والمردود المطلوبين للمنوبة عند توتر (380 فولت) وتردد (50 هرتز)
- في حال كون توتر المنوبة ضمن مجال الـ 400 فولت

- حالة العمل للمنوبة هي حالة العمل المستمر Continuous التي تنص على العمل المستمر (24/24 ساعة) مع زيادة تحميل لمدة ساعة خلال (12 ساعة) .
- عامل الاستطاعة لا يقل عن (0,8).
- المردود لا يقل عن (85%) عند عامل استطاعة (0.8) ويفضل المردود الأعلى.
- العازلية Class H .
- درجة الحماية IP23 .
- من النوع التوافقي بدون الفحومات Brushless ويفضل بيان طريقة تحمل دائرة القصر.
- الربط نجمي مع الحيادي.
- ذاتية التهييج تهييج الكهروني ذو تنظيم ذاتي للتوتر.
- بيان نوع وطراز ومجال عمل المنظم الآلي للتوتر AVR ودرجة تنظيم التوتر في الحالة المستقرة ويفضل أن لا تزيد عن $(\pm 0,5\%)$ وكذلك بيان إمكانية التعيير اليدوي للتوتر وحدود التعيير (بيان طراز المنظم الآلي للتوتر AVR بشكل واضح)
- بيان إنخفاض و تغير التوتر عند تطبيق الحمل .
- محمية ضد التشويش الراديوي والتلفزيوني وبيان كافة الحماية الأخرى المتوفرة بالمنوبة .
- بيان نوع المنوبة ذات أحادية الرولمان (مسند أحادي) أم ثنائية الرولمان .
- مبردة بالهواء مع بيان كمية الهواء اللازمة للتبريد.
- بيان أي مواصفات أو ميزات إضافية للمنوبة.

رابعاً _ مواصفات الكابين الكاتم للصوت :

يجب أن تزود المجموعة بكابين كاتم للصوت ويفضل أن يكون من تصنيع نفس الشركة المصنعة للمجموعة (من بلد المنشأ) ويكون مصنعاً حسب الساندرات والمواصفات العالمية ويتحمل درجات الحرارة الناتجة عن عمل المجموعة وكافة الظروف الجوية المحيطة (حرارة . مطر . ثلوج) ومصنوع من ألواح

		<p>صاح من الحديد الجيد والمحشو من الداخل بالمواد اللازمة لعزل الصوت الناتج عن مجموعة التوليد الكهربائية ، ويجب أن تكون مواد العزل مغطاة ومغلقة بالصفائح ومقاومة للاحتراق والسوائل, ويجب أن يكون الكابين ذو متانة وكثامة ملائم لظروف موقع عمل المجموعة للحماية من ظروف الجو الخارجي ولتأمين العزل والتهوية الكافية للمجموعة الكهربائية، كما يجب أن يكون الكابين بالأبعاد المناسبة لإجراء الصيانات الضرورية للمجموعة بسهولة تامة ، ويجب أن يكون الدهان للأسطح الخارجية والداخلية للكابين إيبوكسي وبالسماكة الكافية ومقاوم للتآكل وذو ثبات للون مع الزمن ولماع , ويجب أن يزود الكابين بالأبواب والفتحات اللازمة والكافية للوصول إلى الأجزاء الرئيسية للمجموعة الكهربائية، والأبواب مزودة بموانع عزل مقاومة للحرارة وتؤمن الكثامة بشكل فني، ومفصلات الأبواب من النوع الجيد غير قابل للصدأ ويفضل أن يكون الكابين مزود بإضاءة داخلية بتوتر مستمر مع مؤقت زمني لإطفاء الإنارة ، وقبضات الأبواب مزودة بقفل.</p> <p>ويجب أن يحقق الكابين مستوى ضجيج لا يزيد عن(80 ديسبل) على بعد متر واحد و(74 ديسبل) على بعد سبعة أمتار ويفضل مستوى الضجيج الأقل (على العارض أن يبين بالتفصيل مواصفات الكابين ومواده وبيان مكان توضع كاتم الصوت لنظام العادم داخل الكابين أم خارجه) وأن تكون موضحة بالكتالوجات الأصلية الصادرة عن الشركة</p>	
24.	Electrocardiogram Machine (ECG)	<p>Electrocardiogram Machine (ECG) 3 channels at least, Portable, operating on AC and with internal rechargeable lithium batteries. Portable, built in thermal printer, rechargeable battery, AC/DC power. Automatic ECG measurement and interpretation, the bidder should be mention the all specifications. With Thermal paper role qty.30</p>	2
25.	Pulse Oximeter (Finger type)	<p>Should have plethismographic wave form with numeric display for SPO2 and Heart rate on LCD/TFT display. 2. Should have a SPO2 range of 0 to 100%.</p>	6

		3. Should have SPO2 accuracy of $\pm 2\%$. 4. Should provide bar graph for pulse strength. 5. Audio and visual alarm for both upper and lower SPO2, Heart rate.		
26.	Ultrasound	Ultrasound Machine : with display 10 inch at least, 220-240V,50Hz and Weight no more 10KGm With Probe Convex 3.5MHZ(abdomen)with angle scanning at least 60°,diameter 60mm at least, works in mode M,B and B,B dual ,it supported with programm for Abdomen, gynecology and maternity Sizes, with printer and thermal paper		4
27.	Examination Table	Approx. Dimensions: 180 cm l x 60cm w x 80cm h - Framework made of rectangular and square steel tubes - Adjustable backrest by hand lever - Two sectioned		4
28.	Sphygmomanomete	Sphygmomanometer For Adults, Anaeroid		6
29.	Stethoscope	Stethoscope For Adults: Binaural, Standard, Dual Head For Adults		12
30.	Blood Glucose Meter	Blood Glucose Meter with 400 Test Strips at least		4
31.	Suction machine	Electric, With 1 Bottle 2 Liters Autoclavable, All filters and component must be reusable and autoclavable. Power supply 220 V, 50-60Hz		6
32.	Thermometer, Digital	NA		6
33.	Nebuliser	Portable, AC power 230v-50hz, W/Accessories: Compressor, W/Accessories: Nebulizer Kits, Mouthpiece, Nosepiece,Airtube Pvc 2m, Airfilter, Adult Mask (Pvc), Child Mask (Pvc) Accessories must be washable and reusable.		4
34.	Digital scale (adult)	Capacity-5-150kg. Graduation-100gr. Precision-25 gr. Washable surface.		4
35.	EENT diagnostic set	Components: Battery handle Ø 28mm for 2 C-type batteries, a base for otoscope and ophthalmoscope head, standard illumination 2.7V. - Otoscope head Pin contact, fits to handle. Swivel-mounted lens: 4x magnifier (removable to introduce instruments)		6

		<p>Auricle specula: size 2, 3 and 4mm, reusable.</p> <ul style="list-style-type: none"> - Ophthalmoscope head - Bent-arm illuminator with pin-contact fitting: stainless steel chrome-plated. - Blade, tongue holder: stainless steel chrome-plated. - Nasal speculum - Laryngeal mirrors: n°3 and 4, stainless steel chrome. - Standard bulb 		
36.	Oxygen Cylinder	Oxygen cylinder: filled with oxygend ,capacity 25 litre, with regulator, hose and mask		4
37.	Insturments table	Insturments table stainless		12
38.	small surgery box	NA		6
39.	Sterilizing Box	NA		4
40.	Gynecology Examination Chair	Platform in two or three sections with traditional, Removable and sliding basin made stainless steel, Back rest and leg rest in Length: 1800 mm, Height:750 mm, adjustable Width: 620 mm,		2
41.	Gyncology insturments	<p>Consist of:</p> <p>KIDNEY DISH, medium, 250x140x40mm, stainless steel, Qty. 1</p> <p>SCISSORS, MAYO, 17 cm, curved, Qty. 1</p> <p>FORCEPS, TOWEL CLAMP, BACKAUS, 13 cm,Qty. 6</p> <p>FORCEPS, SPONGE, FOERSTER, 24cm, serrated jaws, straight,Qty. 2</p> <p>SPECULUM-RETR., KALLMORGEN, size 1 / 70x40mm, set of 2, vag.,Qty. 1</p> <p>SPECULUM-RETR., KALLMORGEN, size 2/ 90x40mm, set of 2, vag.,Qty. 1</p> <p>SPECULUM, AUVARD, 240 x 75 x 38 mm, vaginal, with weight,Qty. 1</p> <p>DILATATOR, UTERINE, HEGAR, double-ended, set of 8 dilatators ,Qty.1</p> <p>SOUND, UTERINE, SIMS, 32 cm, rigid ,Qty.1</p> <p>FORCEPS, SEIZING, POZZI, 25 cm, tenaculum, straight ,Qty.2</p> <p>FORCEPS, SEIZING, KELLY, OVARY, 32 cm, 18 mm jaws, curved,Qty. 1</p> <p>CURETTE, UTERINE, RECAMIER, 8 mm wide, rigid, sharp,Qty. 1</p> <p>CURETTE, UTERINE, RECAMIER, 11 mm wide, rigid, sharp,Qty. 1</p> <p>CURETTE, UTERINE, RECAMIER, 14 mm wide, rigid, sharp,Qty. 1</p>		2

		<p>CURETTE, UTERINE, RECAMIER, 8 mm wide, rigid, blunt ,Qty.1</p> <p>CURETTE, UTERINE, RECAMIER, 11 mm wide, rigid, blunt ,Qty.1</p> <p>CURETTE, UTERINE, RECAMIER, 14 mm wide, rigid, blunt,Qty. 1</p> <p>CURETTE, UTERINE, RECAMIER, 16 mm wide, rigid, blunt,Qty. 1</p> <p>CURETTE, UTERINE, RECAMIER, 20 mm wide, rigid, blunt ,Qty.1</p> <p>BASKET, STERILIZING, 480 x 255x 100mm, + lid,Qty.1</p>		
42.	Autoclave	Autoclave, 38 Litre,with one shelf at least and range of temperature 121 - 132 C°, timer and thermostat , 220V		2
43.	Mobile exam light	length and head adjustable , Power supply : 220V		8
44.	Digital scale(infant)			2
45.	Digital scale(Pediatric)			2
46.	Thermometer	Thermometer tympanic, infrared handheld digital.		2
47.	Length scale			2
48.	X-ray film Viewer(illuminator)	<p>Light power: The minimum luminance for a Negatoscope with an on/off switch must be set greater than 1700cd/m².</p> <p>Wall-Mount,Wall Fixations shall be provided for .</p> <p>Cord , Local Plug</p> <p>Power Supply : 220V/50Hz</p>		2
49.	Portable Ultrasound	<p>Transducers: two probes (abdominal (convex) and trans-vaginal convex)</p> <p>1. The system should have a full field digital scan converter capable of supporting two or more probes with facility to switch between probes. Fast selection of the probes is possible with single key stroke.</p> <p>Capable of using broad band/multi frequency transducer trans-abdominal (convex) and trans-vaginal transducers technology with connectivity of two/three transducers simultaneously.</p> <p>2. Should be microprocessor controlled with high resolution image matrix.</p> <p>3. High resolution integrated monitor</p>		5

	<p>5. Alpha numeric key board with illuminated function key and status display with panel switched and foot control.</p> <p>6. Should have real-time zooming facility dynamic range enlargement and freeze facility. Facility to magnify specific region of image. Scrolling facility should be possible after magnification.</p> <p>7. Should be portable/have handle for transporting machine/should have integrated trolley which is light weight fitted with wheels which can be easily locked.</p> <p>8. Complete software for gynecology, abdominal viscera & complete obstetric measurements (like BPD, CRL, FL, AC, fetal weight etc) which can be activated by easy one touch access.</p> <p>9. The new technology should allow easy and user friendly and special user set up.</p> <p>10. Multifunction electronic calipers for various measurements with track ball facility for image magnifications and guided biopsy.</p> <p>11. Versatile scanner with excellent B and M mode with facility for B+ B and B + M</p> <p>a. Mode preferably with cine memory, facility for possible up gradation.</p> <p>12. Convex array abdominal transducers of 3.5 MHZ (preferably multifrequency probe from 2- 5 MHZ),</p> <p>13. Image archiving .</p> <p>14. Power supply 220 V 50 Hz with internal rechargeable battery .</p>	
--	--	--

Signed..... Date.....

Stamp

Name of Person Signing:

Position in the Company:

Company name:

Annex 2, Detailed Pricing/ Financial Offer;

#	Item	SPECIFICATION	QTY	Unit Price SYP	Total Price SYP
1.	Desk	MDF (Medium-density fiberboard) wood covered with Formica - 120x60cm	14		
2.	Rotating, office, chair	Leather with arms. Hydraulic, rotating, wheels, swivel,	14		
3.	Files cupboard	200*80*40cm - wood - 4 doors	20		
4.	Waiting chair	Without arms, plastic	40		
5.	Stand coats	Wood	12		
6.	Electric fan	standing	14		
7.	Fan	Ground fan on battery	14		
8.	Gas Heater	Indoor Gas heater, Equipped with wheels, Equipped with a gas leak control sensor	4		
9.	Electric kettle	Capacity: 1.2 liter Weight (net) 1.0 kg Color: Black/ White or Stainless steel Voltage: 230 V	10		
10.	oven (3 heads)	3 heads	2		
11.	water cooler	Good Quality , cold/hot with filter	2		
12.	visitor chair ,rigid	Three Seater Waiting Chair - metal and leather	10		
13.	AC(1 ton)	1 Ton - split case with cupboard pipes	12		
14.	Refrigerator	<ul style="list-style-type: none"> •Top mount refrigerator: 1 upper freezer door and 1 lower refrigerator door •Automatic Defrost System includes a timer, a limit switch and heater that melts away frost so you don't have to take everything out of your freezer to melt built-up ice •7.74 cu. ft. fresh food compartment and 2.94 cu. ft. freezer compartment 	6		
15.	Laptop	Intel core i5 with 4 cores, Turbo boost Technology, Hyper Threading, Generation 8th, Cache: 6M , RAM:8G , HDD: 1T,Screen : 15.6 inch, VGA card:2G, Battery: at least 4 hours	8		
16.	Laser Printer	Laser Monochrome Printer, Multifunction: Printer, Copier, Scanner, Printing speed: minimum 18 ppm,Resolution: 1,200 dpi,Paper source: 2 Drawers, Paper feed: Automatic Sheet Feeder, Paper size: A4, A3,Memory Size: Minimum 64 MB, upgradeable	6		
17.	TV LED 32 with receiver	Screen Size: 32" Display Type: LED Colour Depth: 16.7M colours Panel Type: IPS Refresh Rate: 60Hz Aspect Ratio: 16:9 Inputs: Multi Input Resolution: minimum 1920 x 1080	6		

18.	Receiver	HDTV Satellite Receiver 1080p with multi satellites up to 2000 channels at least with HDMI Cable	2		
19.	Photocopier	Functions: coping / printing Colour: Black & white Max. print speed: 18.0 ppm	2		
20.	Telephone	Master, up to 8 lines, multi-transfers	2		
21.	Finger printer	Display:2.8-inch TFT Colour Display/Fingerprint Capacity:3,000/ID Card Capacity: ID Card Capacity/Communication:TCP/IP, USB-Host, Wi-Fi/Standard Functions: Automatic Status Switch, Self-Service Query, Work Code, T9 Input, 9 Digit User ID, DST, Scheduled-bell,SMS,RS232 Printer AC module 1:Exit Button, Door Lock, Alarm,12V OUT,AUX IN/Optional Function: ID Card, MIFARE Card AC module 2: Exit Button, Door Lock, Alarm,12V OUT, AUX IN, Door Sensor, RS485, Wiegand IN/OUT. POE, 3G, Battery Module, ADMS/Power Supply:12V 1.5A/Logs Capacity:100,000	2		
22.	Monitoring Cameras	DVR,Hard,power supply 50A,cable, TV LED 43	20		
23.	20 مولدة كهرباء / K.V.A	المواصفات الفنية لمجموعة التوليد الكهربائية ذات الاستطاعة (20 ك.ف.أ) <u>كاتمة للصوت:</u> على العارض تقديم مجموعة توليد كهربائية استطاعتها (20 ك.ف.أ) عند موقع العمل، عند حالة العمل المستمر Prime power وعند توتر 380 فولت وتردد 50 هرتز لها المواصفات الفنية التالية: <u>أولاً. المواصفات العامة لمجموعة التوليد الكهربائية:</u> _ يجب أن تكون المجموعة المقدمة صناعة أو تجميع إحدى الشركات العالمية المتخصصة ويجب بيان الشركة الصانعة والمجموعة والماركة والطراز وبلد المنشأ للمجموعة بشكل واضح. _ يجب تحديد بلد المنشأ لكل مكونات مجموعة التوليد (محرك الديزل، المنوبة، الكبين، لوحة التحكم، القاطع الكهربائي). _ يجب تقديم شهادة جودة من شركة عالمية موثوقة تثبت التقيد بمواصفات الـ ISO 9001 للشركة الصانعة وشهادة ISO 9001 أو ISO 9002 للشركة المصنعة لمجموعة التوليد الكهربائية وتكون هذه الشهادة سارية الصلاحية بتاريخ تقديم العرض.	1		

— يجب أن يتضمن العرض الفني المعلومات والمعطيات التالية ضمن المواصفات العامة:

1_ استطاعة المجموعة في موقع العمل عند حالة العمل المستمر Prime power لا تقل عن 20 ك.ف.أ/ بعد الأخذ بعين الاعتبار تدني الاستطاعة وفق شروط العمل. [حيث أن حالة عمل المجموعة هي الحالة المستمرة و المعرفة ب (Prime Power/ PRP) والتي تنص :

إن حالة العمل لمجموعة التوليد بشكل مستمر (24/24 ساعة) و بعدد غير محدد من الساعات في السنة وبتوسط حمل متغير حسب المواصفة القياسية ISO 8528-1 مع إمكانية زيادة 10% من الاستطاعة المستمرة للمجموعة لمدة (12 ساعة) وفق المواصفة القياسية ISO 3046-1 .

وعلى العارض أن يبين القيمة العظمى لمتوسط الحمل المتغير Variable Load الذي يمكن استجراره من استطاعة المجموعة ويجب أن لا تقل القيمة العظمى لمتوسط الحمل المتغير Average Load Factor عن 70% من الاستطاعة المستمرة للمجموعة كحد أدنى، ويفضل أن لا تقل تلك القيمة العظمى لمتوسط الحمل المتغير الذي يمكن استجراره من الإستطاعة المستمرة للمجموعة عن 80% .

2_ ظروف التشغيل للمجموعة (موقع العمل):

- درجة الحرارة (-5م° ← +40م° تقريباً).
- الرطوبة النسبية (65%) .

ويجب على العارض تقديم منحنيات وجداول تدني الاستطاعة لكل من المحرك و المنوبة مع درجة الحرارة والارتفاع

ثانياً . المواصفات الفنية لمحرك الديزل:

. يجب أن يكون محرك الديزل صناعة إحدى الشركات العالمية المتخصصة ويجب تقديم شهادة ISO 9001 للشركة الصانعة للمحرك سارية المفعول بتاريخ تقديم العرض، وعلى العارض بيان كافة المواصفات الفنية الأساسية والتصميمية للمحرك في عرضه الفني موثقة وموضحة بال نشرات الفنية وهي:

. الماركة والطراز وبلد المنشأ وسنة الصنع لمحرك الديزل.

. نوع المحرك ديزل رباعي الأشواط عمودي.

. عدد الإسطوانات وترتيبها وتوضع الأسطوانات.

		<p>. قطر الإسطوانة وطول الشوط، متوسط السرعة المكبسية، نسبة الإنضغاط، عدد الصمامات لكل إسطوانة.</p> <p>. سعة الإسطوانة والسعة الكلية للمحرك.</p> <p>. سرعة دوران المحرك (1500 [r.p.m]) ويجب أن تتطابق مع سرعة واتجاه دوران المنوبة.</p> <p>. إستطاعة محرك الديزل:</p> <p>يجب أن تكون استطاعة المحرك كافية لتشغيل المنوبة وإعطاء الاستطاعة الفعلية المطلوبة لمجموعة التوليد وفق الستاندترات العالمية والمواصفات القياسية ISO 8528 & ISO 3046 ويجب أن تحقق استطاعة محرك الديزل الشروط التالية : حالة العمل لمجموعة التوليد هي الحالة المستمرة و المطلوب تقديم استطاعة المحرك عند حالة العمل المستمر المعرف بـ (Prime Power/ PRP) والتي تنص (إن حالة عمل مجموعة التوليد بشكل مستمر (24/24 ساعة) و بعدد غير محدد</p> <ul style="list-style-type: none"> • من الساعات في السنة و بمتوسط حمل متغير حسب المواصفة القياسية ISO 8528-1 مع إمكانية زيادة(10%) من الإسططاعة المستمرة للمجموعة لمدة ساعة خلال (12 ساعة) وفق المواصفة القياسية ISO 3046-1). <p>وعلى العارض أن يبين القيمة العظمى لمتوسط الحمل المتغير Variable Load الذي يمكن استجراها من الإسططاعة المستمرة للمحرك Prime Power .</p> <p>ويجب أن لا تقل القيمة العظمى لمتوسط الحمل المتغير Average Load Factor عن(70%) من الاستطاعة المستمرة للمحرك Prime Power كحد أدنى , ويفضل أن لا تقل تلك القيمة العظمى لمتوسط الحمل المتغير التي يمكن استجراها من الاستطاعة المستمرة للمحرك عن(80%) .</p> <ul style="list-style-type: none"> • الاستطاعة المطلوبة للمحرك هي الاستطاعة الصافية Net Power أي بعد حسم الاستطاعة التي تستهلكها مروحة التبريد من الاستطاعة الكلية للمحرك . • يجب أن يؤخذ بعين الاعتبار منحنيات تخفيض الاستطاعة DE rating مع الحرارة والارتفاع والرطوبة حسب ظروف التشغيل لموقع العمل. 	
--	--	--	--

- يجب أن لا تقل قيمة إستطاعة المحرك الصافي **Net Power** عند حالة العمل المستمر **Prime Power** بعد الأخذ بعين الاعتبار منحنيات تخفيض الإستطاعة **DE rating** بحيث لا تقل عن إستطاعة المنوبة الفعلية في موقع العمل عند نفس حالة العمل المستمر ويفضل وجود احتياطي لإستطاعة المحرك على إستطاعة المنوبة بعد الأخذ بعين الإعتبار تلك الشروط بمحدود (5%) تقريباً .
(علماً أنه لا يؤخذ بالاعتبار مردود المنوبة عند حساب احتياطي إستطاعة المحرك على إستطاعة المنوبة).
- ثالثاً. المواصفات الفنية للمنوبة الكهربائية:
يجب أن تكون المنوبة الكهربائية من صناعة إحدى الشركات العالمية المتخصصة ويجب تقديم شهادة **ISO 9001** للشركة الصانعة للمنوبة سارية المفعول بتاريخ تقديم العرض.
وعلى العارض بيان كافة المواصفات الفنية الأساسية والتصميمية للمنوبة وعرضه الفني موثقة وموضحة بالنشرات الفنية وهي:
- الماركة والشركة الصانعة والطراز وبلد المنشأ وسنة الصنع للمنوبة الكهربائية.
- الاستطاعة المستمرة لا تقل عن **[20 KVA]** عند حالة العمل المستمر **Continuous** في موقع العمل بعد الأخذ بعين الاعتبار تدني الاستطاعة وفق ظروف موقع العمل .
- النوع: ثلاثية الأطوار مع حيادي . رباعية الأقطاب.
- توتر خرج المنوبة 380 فولت أو 400 فولت قابلة للتعبير بحيث يمكن الحصول منها على 380 فولت.
- التردد 50 هرتز.
- سرعة الدوران 1500 دورة/دقيقة.
- على العارض بيان قيم الاستطاعة والمردود المطلوبين للمنوبة عند توتر (380 فولت) وتردد (50 هرتز)
- في حال كون توتر المنوبة ضمن مجال الـ 400 فولت .
- حالة العمل للمنوبة هي حالة العمل المستمر **Continuous** التي تنص على العمل المستمر (24/24 ساعة) مع زيادة تحميل لمدة ساعة خلال (12 ساعة) .
- عامل الاستطاعة لا يقل عن (0,8).

	<ul style="list-style-type: none"> • المردود لا يقل عن(85%) عند عامل استطاعة (0.8) ويفضل المردود الأعلى. • العازلية Class H . • درجة الحماية IP23 . • من النوع التوافقي بدون الفحمت Brushless ويفضل بيان طريقة تحمل دارة القصر. • الربط نجمي مع الحيادي. • ذاتية التهيج تهييج الكتروني ذو تنظيم ذاتي للتوتر. • بيان نوع وطراز ومجال عمل المنظم الآلي للتوتر AVR ودرجة تنظيم التوتر في الحالة المستقرة ويفضل أن لا تزيد عن ($\pm 0,5\%$) وكذلك بيان إمكانية التعبير اليدوي للتوتر وحدود التعبير (بيان طراز المنظم الآلي للتوتر AVR بشكل واضح) • بيان إنخفاض و تغير التوتر عند تطبيق الحمل Transient Voltage dip . • محمية ضد التشويش الراديوي والتلفزيوني وبيان كافة الحماية الأخرى المتوفرة بالمنوبة . • بيان نوع المنوبة ذات أحادية الرولمان (مسند أحادي) أم ثنائية الرولمان . • مبردة بالهواء مع بيان كمية الهواء اللازمة للتبريد. • بيان أي مواصفات أو ميزات إضافية للمنوبة. <p>رابعاً _ مواصفات الكابين الكاتم للصوت :</p> <p>يجب أن تزود المجموعة بكابين كاتم للصوت ويفضل أن يكون من تصنيع نفس الشركة المصنعة للمجموعة (من بلد المنشأ) ويكون مصنوعاً حسب الستاندترات والمواصفات العالمية ويتحمل درجات الحرارة الناتجة عن عمل المجموعة وكافة الظروف الجوية المحيطة (حرارة . مطر . ثلوج) ومصنوع من ألواح صاج من الحديد الجيد والمخشو من الداخل بالمواد اللازمة لعزل الصوت الناتج عن مجموعة التوليد الكهربائية ، ويجب أن تكون مواد العزل مغطاة ومغلقة بالصفائح ومقاومة للاحتراق والسوائل. ويجب أن يكون الكابين ذو متانة وكثافة ملائم لظروف موقع عمل المجموعة للحماية من ظروف الجو الخارجي ولتأمين العزل والتهوية الكافية للمجموعة الكهربائية، كما يجب أن يكون الكابين بالأبعاد المناسبة لإجراء</p>	
--	---	--

		<p>الصيانات الضرورية للمجموعة بسهولة تامة ، ويجب أن يكون الدهان للأسطح الخارجية والداخلية للكابين إيبوكسي وبالسماكة الكافية ومقاوم للتآكل وذو ثبات للون مع الزمن ولماع , ويجب أن يزود الكابين بالأبواب والفتحات اللازمة والكافية للوصول إلى الأجزاء الرئيسية للمجموعة الكهربائية، والأبواب مزودة بجوانات عزل مقاومة للحرارة وتؤمن الكمامة بشكل فني، ومفصلات الأبواب من النوع الجيد غير قابل للصداً ويفضل أن يكون الكابين مزود بإضاءة داخلية بتوتر مستمر مع مؤقت زمني لإطفاء الإنارة ، وقبضات الأبواب مزودة بقفل. ويجب أن يحقق الكابين مستوى ضجيج لا يزيد عن(80 ديسبل) على بعد متر واحد و(74 ديسبل) على بعد سبعة أمتار ويفضل مستوى الضجيج الأقل (على العارض أن يبين بالتفصيل مواصفات الكابين ومواده وبيان مكان توضع كاتم الصوت لنظام العادم داخل الكابين أم خارجه) وأن تكون موضحة بالكتالوجات الأصلية الصادرة عن الشركة</p>			
24.	Electrocardiogram Machine (ECG)	<p>Electrocardiogram Machine (ECG) 3 channels at least, Portable, operating on AC and with internal rechargeable lithium batteries. Portable, built in thermal printer, rechargeable battery, AC/DC power. Automatic ECG measurement and interpretation, the bidder should be mention the all specifications. With Thermal paper role qty.30</p>	2		
25.	Pulse Oximeter (Finger type)	<p>Should have plethismographic wave form with numeric display for SPO2 and Heart rate on LCD/TFT display. 2. Should have a SPO2 range of 0 to 100%. 3. Should have SPO2 accuracy of $\pm 2\%$. 4. Should provide bar graph for pulse strength. 5. Audio and visual alarm for both upper and lower SPO2, Heart rate.</p>	6		
26.	Ultrasound	<p>Ultrasound Machine : with display 10 inch at least, 220-240V,50Hz and Weight no more 10KGm With Probe Convex 3.5MHZ(abdomen)with angle scanning at least 60°,diameter 60mm at least, works in mode M,B and B,B dual ,it supported with programm for Abdomen, gynecology and maternity Sizes, with printer and thermal paper</p>	4		
27.	Examination Table	<p>Approx. Dimensions: 180 cm l x 60cm w x 80cm h - Framework made of rectangular and square steel</p>	4		

		tubes - Adjustable backrest by hand lever - Two sectioned			
28.	Sphygmomanomete	Sphygmomanometer For Adults, Anaeroid	6		
29.	Stethoscope	Stethoscope For Adults: Binaural, Standard, Dual Head For Adults	12		
30.	Blood Glucose Meter	Blood Glucose Meter with 400 Test Strips at least	4		
31.	Suction machine	Electric, With 1 Bottle 2 Liters Autoclavable, All filters and component must be reusable and autoclavable. Power supply 220 V, 50-60Hz	6		
32.	Thermometer, Digital	NA	6		
33.	Nebuliser	Portable, AC power 230v-50hz, W/Accessories: Compressor, W/Accessories: Nebulizer Kits, Mouthpiece, Nosepiece, Airtube Pvc 2m, Airfilter, Adult Mask (Pvc), Child Mask (Pvc) Accessories must be washable and reusable.	4		
34.	Digital scale (adult)	Capacity-5-150kg. Graduation-100gr. Precision-25 gr. Washable surface.	4		
35.	EENT diagnostic set	Components: Battery handle Ø 28mm for 2 C-type batteries, a base for otoscope and ophthalmoscope head, standard illumination 2.7V. - Otoscope head Pin contact, fits to handle. Swivel-mounted lens: 4x magnifier (removable to introduce instruments) Auricle specula: size 2, 3 and 4mm, reusable. - Ophthalmoscope head - Bent-arm illuminator with pin-contact fitting: stainless steel chrome-plated. - Blade, tongue holder: stainless steel chrome-plated. - Nasal speculum - Laryngeal mirrors: n°3 and 4, stainless steel chrome. - Standard bulb	6		
36.	Oxygen Cylinder	Oxygen cylinder: filled with oxygend ,capacity 25 litre, with regulator, hose and mask	4		
37.	Insturments table	Insturments table stainless	12		
38.	small surgery box	NA	6		
39.	Sterilizing Box	NA	4		
40.	Gynecology Examination Chair	Platform in two or three sections with traditional, Removable and sliding basin made instainless steel, Back rest and leg rest adjustableLength: 1800 mm, Height:750 mm, Width: 620 mm,	2		
41.	Gyncology insturments	Consist of: KIDNEY DISH, medium, 250x140x40mm, stainless steel, Qty. 1 SCISSORS, MAYO, 17 cm, curved, Qty. 1	2		

		<p>43. FORCEPS, TOWEL CLAMP, BACKAUS, 13 cm,Qty. 6</p> <p>FORCEPS, SPONGE, FOERSTER, 24cm, serrated jaws, straight,Qty. 2</p> <p>SPECULUM-RETR., KALLMORGEN, size 1 / 70x40mm, set of 2, vag.,Qty. 1</p> <p>SPECULUM-RETR., KALLMORGEN, size 2/ 90x40mm, set of 2, vag.,Qty. 1</p> <p>SPECULUM, AUVARD, 240 x 75 x 38 mm, vaginal, with weight,Qty. 1</p> <p>DILATATOR, UTERINE, HEGAR, double-ended, set of 8 dilators ,Qty.1</p> <p>SOUND, UTERINE, SIMS, 32 cm, rigid ,Qty.1</p> <p>FORCEPS, SEIZING, POZZI, 25 cm, tenaculum, straight ,Qty.2</p> <p>FORCEPS, SEIZING, KELLY, OVARY, 32 cm, 18 mm jaws, curved,Qty. 1</p> <p>CURETTE, UTERINE, RECAMIER, 8 mm wide, rigid, sharp,Qty. 1</p> <p>CURETTE, UTERINE, RECAMIER, 11 mm wide, rigid, sharp,Qty. 1</p> <p>CURETTE, UTERINE, RECAMIER, 14 mm wide, rigid, sharp,Qty. 1</p> <p>CURETTE, UTERINE, RECAMIER, 8 mm wide, rigid, blunt ,Qty.1</p> <p>CURETTE, UTERINE, RECAMIER, 11 mm wide, rigid, blunt ,Qty.1</p> <p>CURETTE, UTERINE, RECAMIER, 14 mm wide, rigid, blunt,Qty. 1</p> <p>CURETTE, UTERINE, RECAMIER, 16 mm wide, rigid, blunt,Qty. 1</p> <p>CURETTE, UTERINE, RECAMIER, 20 mm wide, rigid, blunt ,Qty.1</p> <p>BASKET, STERILIZING, 480 x 255x 100mm, + lid,Qty.1</p>		
42.	Autoclave	Autoclave, 38 Litre,with one shelf at least and range of temperature 121 - 132 C°, timer and thermostat , 220V	2	
43.	Mobile exam light	length and head adjustable , Power supply : 220V	8	
44.	Digital scale(infant)		2	
45.	Digital scale(Pediatric)		2	
46.	Thermometer	Thermometer tympanic, infrared handheld digital.	2	
47.	Length scale		2	
48.	X-ray film Viewer(illuminator)	Light power: The minimum luminance for a Negatoscope with an on/off switch must be set greater than 1700cd/m ² . Wall-Mount,Wall Fixations shall be provided for . Cord , Local Plug Power Supply : 220V/50Hz	2	
49.	Portable Ultrasound	Transducers: two probes (abdominal (convex) and trans-vaginal convex)	5	

		<p>1. The system should have a full field digital scan converter capable of supporting two or more probes with facility to switch between probes. Fast selection of the probes is possible with single key stroke.</p> <p>Capable of using broad band/multi frequency transducer trans-abdominal (convex) and trans-vaginal transducers technology with connectivity of two/three transducers simultaneously.</p> <p>2. Should be microprocessor controlled with high resolution image matrix.</p> <p>3. High resolution integrated monitor</p> <p>5. Alpha numeric key board with illuminated function key and status display with panel switched and foot control.</p> <p>6. Should have real-time zooming facility dynamic range enlargement and freeze facility. Facility to magnify specific region of image. Scrolling facility should be possible after magnification.</p> <p>7. Should be portable/have handle for transporting machine/should have integrated trolley which is light weight fitted with wheels which can be easily locked.</p> <p>8. Complete software for gynecology, abdominal viscera & complete obstetric measurements (like BPD, CRL, FL, AC, fetal weight etc) which can be activated by easy one touch access.</p> <p>9. The new technology should allow easy and user friendly and special user set up.</p> <p>10. Multifunction electronic calipers for various measurements with track ball facility for image magnifications and guided biopsy.</p> <p>11. Versatile scanner with excellent B and M mode with facility for B+ B and B + M a. Mode preferably with cine memory, facility for possible up gradation.</p> <p>12. Convex array abdominal transducers of 3.5 MHZ (preferably multifrequency probe from 2-5 MHZ),</p> <p>13. Image archiving .</p> <p>14. Power supply 220 V 50 Hz with internal rechargeable battery .</p>			
	Total price: numbers				
	Total price: writing				

Note: Prices should be inclusive of all applicable taxes, transportation to the final delivery address, loading and offloading, transit Insurance, and all other related costs involved.

I acknowledge that the above information and documents are reliable and correct and I agree with the general terms and conditions of the Syrian Arab Red Crescent Society.

Name: Position: Company:
Signature: Date: Company Stamp:



ملف المورد / نموذج تسجيل رقم.....

يرجى ملء هذا الاستبيان من أجل التسجيل. سيتم التعامل بسرية مع المعلومات الواردة في هذا الاستبيان. يرجى إرفاق جميع الوثائق الأخرى المطلوبة في الاستبيان.

1. اسم الشركة:

العنوان البريدي:

المدينة:

أشخاص التواصل:

الهاتف:

فاكس:

البريد الإلكتروني:

الموقع الإلكتروني:

2. نوع المنظمة (يرجى الاختيار)

فردي شراكة غير ربحية

شركة خاصة محدودة المسؤولية شركة عامة محدودة المسؤولية

أخرى () الرجاء التوضيح:

.....

سنة التأسيس: وفقاً لقوانين

تداول الأسهم في

يرجى إرفاق نسخة عن شهادة التسجيل

3. نوع العمل (يرجى الاختيار):

صناعي بناء تجارة استشاري

مقدم الخدمة (مثل النقل، والتخزين، وضبط الجودة، وغيرها)

أخرى (يرجى الشرح):

.....

الرجاء وصف النشاط التجاري الرئيسي الخاص بشركتك

.....

.....

.....

يرجى الإشارة في الصفحة 6 الى أبرز المجموعات السلعية / الخدمات التي تقدمها الشركة الخاصة بك.

4. حجم العمل (يرجى تقديم آخر نسخة مدققة عن البيانات المالية الخاصة بك)

نهاية الدورة (آخر سنة مالية) المنتهية ب: ___ / ___ / ___ (العملة)

(السنة المالية السابقة) المنتهية ب: ___ / ___ / ___ (العملة)

(السنة المالية السابقة) المنتهية ب: ___ / ___ / ___ (العملة)

التقارير السنوية عن السنوات الثلاث الماضية.

عدد الموظفين:

عدد المكاتب الدولية:

مواقع المصانع:

عدد الشركات المصنعة:

عدد المستودعات:

البلدان التي تصدر لها:

.....

5. الشركات المنتمية/القابضة/الفرعية

الاسم	العنوان	طبيعة الانتماء

يرجى ارفاق الهيكل التنظيمي.

6. الأشخاص الموكلين لتوقيع المزادات (العروض و العقود)

الاسم	التوصيف	الهاتف/الفاكس

7. المعلومات المصرفية:

الاسم:

العنوان:

رقم الحساب: رمز SWIFT.....

IBAN:

8. مراجع

أ. المعاملات التجارية الأخيرة: (غير مطلوبة إذا كانت مجددة وكنت قد زودت الاتحاد الدولي لجمعيات الصليب الأحمر والهلال الأحمر/الهلال الأحمر العربي السوري بالسلع أو الخدمات خلال ال 24 شهر الماضي)

التاريخ(اليوم/الشهر/السنة)	الخدمة أو المنتج	القيمة بالعملة ()	المشتري/الاتصال والهاتف

ب. يرجى تحديد معايير ضمان الجودة الخاصة بك

.....

.....

9. أسماء المالكين أو الشركاء

- المالكين:

- المدير التنفيذي:

- المدير المالي:

10. الاعتبارات البيئية

هل حددت التأثيرات البيئية الرئيسية / مخاطر النشاط الخاص بك؟

نعم لا (إذا كانت الإجابة بنعم، يرجى تقديم تفاصيل)

هل قمت بإعداد أي سياسة أو أهداف من أجل الحد من الآثار البيئية لديك؟
نعم لا (إذا كانت الإجابة بنعم، يرجى تقديم تفاصيل)

هل هناك أية موارد مخصصة لإدارة البيئة، (أي النظم، فريق)؟
نعم لا (إذا كانت الإجابة بنعم، يرجى تقديم تفاصيل)

11. شروط الدفع: يقوم الاتحاد الدولي بتقديم المدفوعات في غضون 30 يوما بعد استلام البضاعة على أن تكون بحالة جيدة ومرفقة بجميع الوثائق المطلوبة. المدفوعات ستكون فقط مقابل فاتورة المورد وخضوع البضائع لمطابقة المواصفات. لمعلوماتك، وثائق ومتطلبات الاتحاد الدولي كثيرا ما تتضمن شهادة تسليم موقعة من الممثل المحلي للاتحاد على النطاق الدولي. يرجى الانتباه الى أن عدم قبول أي من هذه الشروط قد تمنع الشركة من أن تكون مورد محتمل.

12. ضمان الجودة (يرجى إرفاق أي وثائق أو شهادات تدل على ضمان الجودة)

13. الشروط والمعايير العامة: يرجى القراءة بعناية لكافة الشروط والأحكام التي تتعلق بالاتحاد الدولي لجمعيات الصليب الأحمر والهلال الأحمر وتأكيد الموافقة على هذه الشروط والأحكام النهائية عن طريق التوقيع.

14. مبادئ السلوك: على المورد الذي يسعى للعمل مع الاتحاد أن يحترم المبادئ التالية:

- أخلاقيات الأعمال: على المورد أن يحافظ على أعلى درجة من أخلاقيات العمل لدى التعامل مع الاتحاد .
- الشفافية في تقديم المعلومات: لا يجوز للمورد أن يشارك في أي من النشاطات الاحتيالية أو تحريف المعلومات و الحقائق بغرض التأثير على عملية الاختيار لصالحه.
- المنافسة العادلة: لا يجوز للمورد المشاركة في أي تواطؤ أو أي من الممارسات القسرية الفاسدة.

في حال اكتشاف الاتحاد الدولي خلال عملية التسجيل أو أي وقت من الأوقات أن المورد ينتهك أي من المبادئ المذكورة أعلاه، فقد يتم رفض طلب التسجيل و اعتباره أنه غير مؤهل.

ان احترام حقوق الإنسان الأساسية ومعايير العمل المنصوص عليها في الشروط والأحكام العامة يجب أن تكون مقبولة من قبلك كشرط من شروط التعاقد مع الاتحاد الدولي. لذلك فإن أي رفض لهذه الشروط تشكل سببا لرفض طلب تسجيل المورد و إن أي محاولة انتهاك خلال العقد ستشكل سببا لإنهاء العقد.

15. رفض التسجيل: قد يتم رفض طلب التسجيل للأسباب التالية:

- الإفلاس أو قرار بعدم الكفاءة القانونية.
- إدانة جنائية أو الحكم المدني ضدك أو ضد العضو المنسوب (أو من يعادله) وذلك لارتكاب أي جريمة مما يدل على عدم وجود نزاهة العمل أو الصدق التجاري.
- أسباب لاشتباه في انتهاك معايير الاتحاد (انتهاكا للمبادئ الأساسية أو المعايير الاجتماعية والأخلاقية)

- رفض أي من مبادئ السلوك أو أي رفض لاحترام حقوق الإنسان الأساسية ومعايير العمل.
- رفض معايير الدفع المتعلقة بالاتحاد الدولي لجمعيات الصليب الأحمر والهلال الأحمر.

16. الشهادة: إن الموقع أدناه، الموقع الموكل من الشركة يتعهد بأن المعلومات المقدمة في هذه الوثيقة هي حقيقية وصحيحة لأفضل ما لديه / معرفتها على أي من الصفحات المرفقة. والشيء نفسه بالنسبة لموافقة الاتحاد الدولي فيما يخص الإقرار بالدفع في غضون 30 يوم.

الاسم والمنصب:

التوقيع: التاريخ:

قائمة اللوازم والخدمات المقدمة

السلع / الخدمات المقدمة

السلع:

- _____ منتجات زراعية
- _____ لحوم وأسماك وفواكه وخضراوات وزيت ودهون
- _____ منتجات الألبان
- _____ منتجات الحبوب المطحونة
- _____ المنسوجات والأقمشة
- _____ الأقمشة والملابس
- _____ المنتجات الجلدية والأحذية
- _____ الخشب والمنتجات الخشبية
- _____ الورق والمنتجات الورقية
- _____ المنتجات البترولية المكررة
- _____ منتجات صيدلانية واللقاحات
- _____ المنتجات الكيماوية والمطاط والمنتجات البلاستيكية
- _____ الزجاج والمنتجات الزجاجية
- _____ الأثاث والسلع غير المعدنية الأخرى الغير مذكورة في مكان آخر.
- _____ المنتجات المعدنية المصنعة غير الآلات و المعدات
- _____ آلات الأغراض العامة
- _____ آلات الأغراض الخاصة
- _____ مكتب - المحاسبة وآلات الحوسبة
- _____ أجهزة كهربائية ومعدات الاتصالات
- _____ المعدات السمعية والبصرية
- _____ المعدات الطبية، المعدات الدقيقة
- _____ معدات النقل

خدمات:

- _____ العمارة والهندسة والبناء
_____ موارد المياه
_____ خدمات الصيانة والإصلاح
_____ خدمات قانونية
_____ الخدمات المالية والتأمين
_____ خدمات التجارة و الأعمال.
_____ النقل والتخزين ومناولة المواد
_____ تكنولوجيا المعلومات
_____ تكنولوجيا التصنيع ومراقبة الجودة
_____ دعم المنتج والتعبئة والتغليف
_____ الدعم المكتبي والطباعة وخدمات الطرود الصغيرة.

يرجى الانتباه الى أن القائمة أعلاه ليست شاملة. لكنها تمثل السلع والخدمات الأكثر طلباً من قبلنا.